

Division of Petroleum & Chemical Safety

Facility Details

Facility Number:	2021102
Status:	Active
Facility Name:	Parkridge Shell, LLC
Address:	1200 W. Touhy Ave. Park Ridge, IL 60056
County:	Cook
Property Parcel:	09-26-319-016-0000
Facility Type:	Attended Self-Service Station
Owner Type:	Private
Green Tag Decal:	Y002002
Green Tag Issue Date:	7/26/2023
Green Tag Expiration Date:	12/31/2025

Owner Details

Owner Name:	Parkridge Business, Inc.
Owner Address:	1200 W. Touhy Ave. Park Ridge, IL 60068
Owner Status:	Current Owner
Purchase Date:	9/19/2019
Type of Financial Responsibility:	Commercial Insurance
Financial Responsibility Reporting Due Date:	11/9/2024

Motor Fuel Dispensing Permits

MFD Permit Type	Issue Date	Expiration Date
Self Service	7/26/2023	12/31/2025

Owner Summary

[Click for Facility/Tank Ownership history.](#)

Owner Number	Owner Name	Owner Status	Purchase Date
U0040315	Parkridge Business, Inc.	Current Owner	9/19/2019
U0036838	Park Ridge Shell, LLC	Former Owner	1/1/2013
U0035735	True North Energy, LLC	Former Owner	3/8/2010
U0027449	Equilon Enterprises, LLC	Former Owner	7/1/1973
U0013849	Shell Oil Products	Former Owner	12/31/1967
U0031151	Shell Oil Products US c/o Gilbarco Veeder-Root	Former Owner	

Permits (Unexpired)

[Click for permit history.](#)

Permit Number	Type	Status	OSFM Receive Date	Issue Date	Expiration Date	Documents
00019-2024LIN	Lining Inspection	Approved / Issued	1/6/2024	1/8/2024	7/9/2024	Documents

Notice of Violations (Current)

NOV Number: E0020241233 (Pending) **Issue Date:** 4/25/2024 **Expiration Date:** 6/24/2024 [View NOV Form](#)

Tanks	Violation
Facility	Due to a red tagged tank(s) at this facility, after 60 days from the issuance date of this NOV, in the absence of full compliance, all tanks shall be red tagged

IEMA Numbers Associated with the Facility

No IEMA Numbers Found

UST Fund Eligibility and Deductibility Determinations

IEMA Number	Status	OSFM Received Date	OSFM Response Date	Deductible	Letter
96-0203	Eligible	4/19/1996	5/10/1996	\$15,000	
06-1433	Eligible	8/16/2007	9/4/2007	\$15,000	


Tank Information

[Pay Tank Fees Online](#)

Tank Number 1

Capacity:	10000	Petroleum Use:	
Product:	Gasoline - Regular	CERCLA Substance:	
Status:	Currently in use	CAS Code:	
Regulated Status:	Federal	Removed Date:	
OSFM First Notify Date:	4/20/1986	Abandoned Material:	
Current Age:	45	Abandoned Date:	
Install Date:	1/1/1979	Red Tag Issue Date:	
Last Used Date:		Fee Due:	\$0.00
Product Date:	1/1/1979		

Equipment

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Corrosion Prot - Piping	Sacrificial Anode Flex Connector	5/16/2023	5/16/2026
Corrosion Prot - Piping	Fiberglass Non-Corrosive	N/A	N/A
Corrosion Prot - Tank	Lining Materials Internal	1/24/2024	1/24/2029
Corrosion Prot - Tank	Fiberglass Non-Corrosive	N/A	N/A
Leak Detect - Piping	Electronic Pressurized Line Leak Detection	5/15/2024	5/15/2025
Leak Detect - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	5/15/2024	5/15/2025
Overfill Prev Device	Overfill Drop Tube Valve	5/15/2024	5/15/2027
Piping	Fiberglass Single Wall Piping	N/A	N/A
Piping	Single Wall STP/Tanktop Sump		
 Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A
Spill Contain Device	Single Wall Spill Bucket	5/15/2024	5/15/2027
Tank	Fiberglass Single Wall	N/A	N/A

Additional Tests

Equipment Type	Equipment	Test Type	Test Result	Test Date
Piping	Fiberglass Single Wall Piping	Precision Test	Pass	5/15/2024
Tank	Fiberglass Single Wall	Precision Test (Tank)	Pass	1/25/2024

Tank Number 2

Capacity:	10000	Petroleum Use:	
Product:	Gasoline - Regular	CERCLA Substance:	
Status:	Currently in use	CAS Code:	
Regulated Status:	Federal	Removed Date:	
OSFM First Notify Date:	4/20/1986	Abandoned Material:	
Current Age:	45	Abandoned Date:	

Install Date:	1/1/1979		Red Tag Issue Date:	
Last Used Date:			Fee Due:	\$0.00
Product Date:	1/1/1979			

Equipment

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Corrosion Prot - Piping	Sacrificial Anode Flex Connector	5/16/2023	5/16/2026
Corrosion Prot - Piping	Fiberglass Non-Corrosive	N/A	N/A
Corrosion Prot - Tank	Lining Materials Internal	1/24/2024	1/24/2029
Corrosion Prot - Tank	Fiberglass Non-Corrosive	N/A	N/A
Leak Detect - Piping	Mechanical Other Non-vented check valve	N/A	N/A
Leak Detect - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	5/15/2024	5/15/2025
Overfill Prev Device	Overfill Drop Tube Valve	5/15/2024	5/15/2027
Piping	Fiberglass Single Wall Piping	N/A	N/A
Piping	Single Wall STP/Tanktop Sump		
↳ Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A
Spill Contain Device	Single Wall Spill Bucket	5/15/2024	5/15/2027
Tank	Fiberglass Single Wall	N/A	N/A

Additional Tests

Equipment Type	Equipment	Test Type	Test Result	Test Date
Piping	Fiberglass Single Wall Piping	Precision Test	Pass	5/15/2024
Tank	Fiberglass Single Wall	Precision Test (Tank)	Pass	2/2/2024

Tank Number 3

Capacity:	8000		Petroleum Use:	
Product:	Gasoline - Premium		CERCLA Substance:	
Status:	Currently in use		CAS Code:	
Regulated Status:	Federal		Removed Date:	
OSFM First Notify Date:	4/20/1986		Abandoned Material:	
Current Age:	54		Abandoned Date:	
Install Date:	1/1/1970		Red Tag Issue Date:	
Last Used Date:			Fee Due:	\$0.00
Product Date:	1/1/1970			

Equipment

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Corrosion Prot - Piping	Sacrificial Anode Flex Connector	5/16/2023	5/16/2026
Corrosion Prot - Piping	Fiberglass Non-Corrosive	N/A	N/A
Corrosion Prot - Tank	Lining Materials Internal	1/24/2024	1/24/2029
Corrosion Prot - Tank	Fiberglass Non-Corrosive	N/A	N/A
Leak Detect - Piping	Electronic Pressurized Line Leak Detection	5/15/2024	5/15/2025
Leak Detect - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	5/15/2024	5/15/2025
Overfill Prev Device	Overfill Drop Tube Valve	5/15/2024	5/15/2027

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Piping	Fiberglass Single Wall Piping	N/A	N/A
Piping	Single Wall STP/Tanktop Sump		
↳ Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A
Spill Contain Device	Single Wall Spill Bucket	5/15/2024	5/15/2027
Tank	Fiberglass Single Wall	N/A	N/A

Additional Tests

Equipment Type	Equipment	Test Type	Test Result	Test Date
Piping	Fiberglass Single Wall Piping	Precision Test	Pass	5/15/2024
Tank	Fiberglass Single Wall	Precision Test (Tank)	Pass	1/25/2024

Tank Number 4

Capacity:	550	Petroleum Use:	
Product:	Used Oil	CERCLA Substance:	
Status:	Removed	CAS Code:	
Regulated Status:	Federal	Removed Date:	8/17/1998
OSFM First Notify Date:	4/20/1986	Abandoned Material:	
Current Age:	32	Abandoned Date:	
Install Date:	1/1/1966	Red Tag Issue Date:	
Last Used Date:	8/15/1998	Fee Due:	\$0.00
Product Date:			

Equipment

Equipment Type	Equipment	Last Passing Date	Test Expire Date
----------------	-----------	-------------------	------------------

Additional Tests

Equipment Type	Equipment	Test Type	Test Result	Test Date
----------------	-----------	-----------	-------------	-----------

Tank Number 5

Capacity:	1000	Petroleum Use:	Consumptive Use on Premises for Heating
Product:	Heating Oil	CERCLA Substance:	
Status:	Removed	CAS Code:	
Regulated Status:	State	Removed Date:	2/6/1996
OSFM First Notify Date:	10/10/1995	Abandoned Material:	
Current Age:	36	Abandoned Date:	
Install Date:	1/1/1960	Red Tag Issue Date:	
Last Used Date:	1/1/1986	Fee Due:	\$0.00
Product Date:	1/1/1960		

Equipment

Equipment Type	Equipment	Last Passing Date	Test Expire Date
----------------	-----------	-------------------	------------------

Additional Tests

Equipment Type	Equipment	Test Type	Test Result	Test Date
----------------	-----------	-----------	-------------	-----------

Tank Number 6

Capacity:	1000	Petroleum Use:	None
Product:	Used Oil	CERCLA Substance:	
Status:	Out of service	CAS Code:	
Regulated Status:	Federal	Removed Date:	
OSFM First Notify Date:	10/19/1998	Abandoned Material:	
Current Age:	25	Abandoned Date:	
Install Date:	8/15/1998	Red Tag Issue Date:	1/24/2024
Last Used Date:	9/3/2019	Fee Due:	\$0.00
Product Date:	8/18/1998		

Equipment

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Corrosion Prot - Piping	Sacrificial Anode Flex Connector	8/16/2019	8/16/2022
Corrosion Prot - Piping	Fiberglass Non-Corrosive	N/A	N/A
Corrosion Prot - Tank	Fiberglass Non-Corrosive	N/A	N/A
Leak Detect - Piping	Gravity Feed	N/A	N/A
Leak Detect - Tank	Automatic Tank Gauging Veeder Root TLS 350 with CSLD	9/10/2019	9/10/2020
Leak Detect - Tank	Non-Discriminating Interstitial Monitoring Sensors	9/10/2019	9/10/2020
Overfill Prev Device	Less than 25 gallon fills	N/A	N/A
Piping	Fiberglass Double Wall	N/A	N/A
Piping	Single Wall STP/Tanktop Sump		
↳ Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A
Spill Contain Device	Single Wall Spill Bucket	9/23/2021	9/23/2024
Tank	Fiberglass Brine Filled Double Wall	N/A	N/A

Additional Tests

Equipment Type	Equipment	Test Type	Test Result	Test Date
----------------	-----------	-----------	-------------	-----------

Dispenser Information**NameID 1/2**

Status:	Active		
Equipment Type	Equipment	Last Passing Date	Test Expire Date
Dispenser	Single Wall UDC Sump		
↳ Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A

NameID 3/4

Status: Active

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Dispenser	Single Wall UDC Sump		
↳ Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A

NameID 5/6Status: Active

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Dispenser	Double Wall UDC Sump		
↳ Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A

NameID 7/8Status: Active

Equipment Type	Equipment	Last Passing Date	Test Expire Date
Dispenser	Single Wall UDC Sump		
↳ Leak Detect - Piping	Piping Sump Sensors Not Regulated	N/A	N/A

MFD Motorfuel Dispensing Forms**No Forms Found**